



FIRELAB

CERTIFICATE

This is to certify that

Helm AWL Ventilator

Size:	1770 mm X 2650 mm
Material:	Steel
Fire activation:	93 °C Fusible link
Operating devices:	BELIMO® SF230A Spring return actuator Enhancer, Linear Drive Actuator. 230 V, 600 N, 150 mm

is classified as follows

Reliability:	Re 2 000
Wind Load:	WL 750
Resistance to Heat:	B ₃₀₀ 30

when tested in accordance with

BS EN 12101-2:2017
(Annexures C, F and G)

Signed:

Certificate Number: FTC 19/326 (2)

Report validity: February 2025

(For more details refer to Test Report number FTC 19/326 (2))

Reg nr: 2005/087037/23 • Tel: + 2712 349 2929 • info@firelab.co.za

CONSOLIDATED STEEL INDUSTRIES (PTY) LTD
CORNER OF QUALITY AND BARLOW ROADS, ISANDO, KEMPTON PARK, GAUTENG • +27 11 898 2900

